



MTBF Summary

We of:
OnLogic, Inc.
35 Thompson Street
South Burlington, VT 05403
USA

OnLogic, BV
De Boedingen 39,
4906 BA Oosterhout
The Netherlands

hereby declare that the following for Equipment:

Rugged Power Supply model(s): PS1000-1

Calculation Model: Telcordia SR-332

Temperature (°C)	Input Voltage	Failure Rate(Failures /10 ⁹ Hours)	MTBF Value (Hours)
25	100 Vac / 60 Hz	695.397095	1438027
40	100 Vac / 60 Hz	1203.198975	831118
40	240 Vac / 50 Hz	1174.939209	851108

Test Report : MTBF Report-HPL1000A-S 100Vac 25°C, MTBF Report-HPL1000A-S 100Vac 40°C, MTBF Report-HPL1000A-S 240Vac 40°C

By:

CJ Lahaie

Date 2023-10-18
(YYYY-MM-DD)

Name: CJ Lahaie
Title: Regulatory Specialist